

SANITARY CERTIFICATE

This is to certify that the management of St. Joseph High School,
4-4-8, Guttala Bazar, Khammam (Urban Mdl), Khammam District has provided pure
•drinking water for students. The classes are sufficient for the maximum number of
pupils and they are properly ventilated and lighted. In all aspects the sanitation is
satisfactory as per the inspection report submitted by the District Surveillance Officer,
Integrated Disease Surveillance Programme (IDSP), Khammam.

This certificate is valid from 10-02-2026 to 09-02-2027.

Date: 10-02-2026
Station: Khammam.



[Handwritten signature]
District Medical and Health Officer
Khammam

[Handwritten signature]
Dist. Medical & Health Officer
Khammam

WATER QUALITY MONITORING LABORATORY, MB INTRA DIVISION KHAMMAM

CHEMICAL ANALYSIS REPORT

S.N O	Name of the Mandal	Name of the Grampanchayat	Habitatio n	Sample Location	Source	DATE OF COLLECTION	Turbidity	pH	E.C	TDS	Total Alkalinity (as cacO ₃)	Total Hardness (as cacO ₃)	Calcium (as ca)	Chloride (as cl-)	Fluoride (as F-)	Nitrate (as NO ₃)	Sulphate (as SO ₄)	Iron (as fe)
							NTU		µS/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
							5	6.5-8.5		500	200	200	75	250	1.0	45	200	0.3
							-	NR	2500	2000	600	600	200	1000	1.5	NR	400	NR
1	2	3	4	5	6	8	9	10	11	12	13	14	15	16	17	18.0	19	20
1	Khammam	Khammam	Khammam	St.Joseph CBSE High School, Guttalabazar, Khammam	BW	13.02.2026	0.1	7.47	990	643	360	368	88	113	1.09	35.42	74.00	0.15

Note:-This is to Certify that the above given source is Chemically Satisfactory for human Consumption. All parameters are within the permissible limit. It is fit for drinking.

BACTERIOLOGICAL ANALYSIS REPORT

S.NO	Mandal	G.P/Habit ation	Source	Location	Date of Collectio n	Bacteria/ 100ml of Sample (MPN)	Result
1	2	3		3	4	5	6
1	Khammam	Khammam	BW	St.Joseph CBSE High School, Guttalabazar, Khammam	13.02.2026	NIL	This source water is suitable for drinking.

[Signature]
Chemist/Microbiologist
WQML, Khammam

[Signature]
Assistant Engineer
MB Intra SD, Khammam